

# IEC 61850 Certificate Level A<sup>1</sup>

No. 10016112-OPE/INC 16-1641

**Issued to:**

OJSC NIPOM  
10 Zelenaya str.  
606007 Dzerzhinsk  
Nizhegorodskaya region  
Russian Federation

**For the server product:**

P0301 Line protection relay  
Software version: 16.02.1  
Windows 7 professional, SP1  
S/N: 502327

The server product has not been shown to be non-conforming to:

## IEC 61850 First Edition Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10, the UCA International Users Group Server Device Test Procedures version 3.03, the product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in Line Protection Relay P0301 v1.0", "Model Implementation Conformance Statement for the IEC 61850 interface in Line protection relay P0301 v1.0" and "ISSUES Implementation Conformance Statement for the IEC 61850 interface in Line protection relay P0301 v1.0" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in Line Protection Relay P0301 v1.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (21/24)	9a GOOSE Publish (10/12)
2 Data Sets (3/6)	9b GOOSE Subscribe (11/11)
2+ Data Set Definition (24/24)	12a Direct Control (3/11)
4 Setting Group Selection (3/3)	13 Time Synchronization (2/5)
5 Unbuffered Reporting (17/18)	14 File Transfer (6/7)
6 Buffered Reporting (24/27)	

This certificate includes a summary of the test results as carried out at NTC FSK UES in Russia with UniCA 61850 Client Simulator 4.29.03 with test suite 3.29.00 and UniCA 61850 Analyzer 5.29.02. This document has been issued for information purposes only, and the original paper copy of the DNV GL verification report No. 10016112-OPE/INC 16-1640 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by OJSC NIPOM. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, February 18, 2016



**M. Adriaensen**  
Head of Department  
Operational Excellence

Issued by:



DNV KEMA is now DNV GL



**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System



Applicable Test Procedures from the UCA International Users Group Server Device Test Procedures version 3.03

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	AssN3, Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
2+: Data Set Definition	Dset2, Dset3, Dset4, Dset5, Dset6, Dset7, Dset8, Dset9 DsetN1cd, DsetN2, DsetN3, DsetN4, DsetN5, DsetN6, DsetN7, DsetN8, DsetN9, DsetN10, DsetN11, DsetN12, DsetN13, DsetN14,	DsetN15a, DsetN15b
4: Setting Group Selection	Sg1, SgN1a, Sg3	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp9, RpN1, RpN2, RpN3, RpN4, RpN8	Rp6, Rp7, Rp8, Rp10, Rp11, Rp12, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br9, Br20, Br21, Br22, Br25, Br26, Br27, Br28, BrN1, BrN2, BrN3, BrN4, BrN5, BrN8	Br6, Br7, Br8, Br10, Br11, Br12
9a: GOOSE Publish	Gop2, Gop3, Gop4, Gop9, Gop10a	Gop1, Gop6, Gop7, Gop10b, GopN1
9b: GOOSE Subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	Gos1b, Gos4
12a: Direct Control	CtlN3, DOns1	DOns3
13: Time Sync	Tm1, Tm2	
14: File Transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c